

NR		POMIESZCZENIE	POW.	WYS.	KUB.	KROTNOŚĆ WYMIAN	T naw. zima	T w pom. zima	Vnaw	Vwyw	AHU naw	AHU wyw	UWAGI
[-]		[-]	[m <sup>2</sup> ]	[m]	[m <sup>3</sup> ]	[1/h]	[C]	[C]	[m <sup>3</sup> /h]	[m <sup>3</sup> /h]	[-]	[-]	[-]
<b>POZIOM -1</b>													
B	-1.01	REZERWA / MAGAZYN	409,17	2,7	1104,8	3,7	16	16	4100	4100	B-NR1	B-WR1	
B	-1.02	REZERWA / MAGAZYN	171,68	2,7	463,54	2,4	16	16	1100	1100	B-NR2	B-WR2	
F.MAG	-1.26A	KOMUNIKACJA	89,40	2,5	223,50	1,5	20	20	340	340	B-N6	B-W6	
B.MN	-1.01	POK. KIEROWNIKA	15,43	3,0	46,29	2,6	22	20	120	50	B-N14	B-W14	
B.MN	-1.01	ŚLUZA DOZYMETRYCZNA	7,13	3,0	21,39	6,1	20	20	110	130	C-N1	C-W1	
B.MN	-1.01A	SZATNIA	6,32	3,0	18,96	5,3	20	24	100	0	C-N1	z pom. B.MN-1.01B	
B.MN	-1.01B	UMYWALNIA	5,57	3,0	16,71	6,0	-	24	0	100	z pom. B.MN-1.01A	C-WC1	
B.MN	-1.01C	SZATNIA	6,32	3,0	18,96	5,3	20	24	100	0	C-N1	z pom. B.MN-1.01D	
B.MN	-1.01D	UMYWALNIA	5,79	3,0	17,37	5,8	-	24	0	100	z pom. B.MN-1.01C	C-WC1	
B.MN	-1.02	ŁAZIENKA	3,92	2,5	9,80	7,1	-	24	0	70	z B-MN_-1,01	B-WC1	
B.MN	-1.03	SEKRETARIAT	23,29	3,0	70,47	1,6	22	20	110	80	B-N14	B-W14	
B.MN	-1.04	ZAPLECZE	2,23	3,0	6,69	4,5	-	20	0	30	z B-MN_-1,03	B-W14	
B.MN	-1.05	KORYTARZ TECHNICZNY	83,49	2,5	208,73	1,8	20	16	380	180	B-N6	B-W6	
B.MN	-1.06	POM. ELEKTRYCZNE	7,63	3,0	23,16	2,2	20	16	50	50	B-N6	B-W6	
B.MN	-1.07	POM. TELETECHNICZNE	3,98	3,0	11,91	4,2	20	16	50	50	B-N6	B-W6	
B.MN	-1.08	ADMINISTRACJA	23,57	3,0	70,38	1,6	22	20	110	110	B-N14	B-W14	
B.MN	-1.11	POM. SZKOLENIOWE	19,39	3,0	58,41	7,7	20	20	450	450	B-N6	B-W6	
B.MN	-1.15	POKÓJ OPISÓW	24,13	3,0	72,90	1,6	20	22	120	120	B-N14	B-W14	
B.MN	-1.16	POKÓJ OPISÓW	24,97	3,0	74,91	1,6	20	22	120	120	B-N14	B-W14	
B.MN	-1.17	WC MĘSKI	7,05	3,0	21,72	4,6	-	20	0	100	z B-MN_-1,18	B-WC1	
B.MN	-1.18	POCZEKALNIA	26,87	3,0	80,49	5,0	20	20	400	200	B-N6	B-W6	
B.MN	-1.19	WC DAMSKI	6,77	3,0	19,44	5,1	-	20	0	100	z B-MN_-1,18	B-WC1	
B.MN	-1.20	PRÓBY WYSIŁKOWE	24,46	3,0	73,26	2,0	22	24	130	150	B-N14	B-W14	
B.MN	-1.21	POM. SOCJALNE	25,01	3,0	75,24	4,8	20	20	270	360	B-N6	B-WK1	
B.MN	-1.22	GAB. BADAŃ	21,56	3,0	65,73	2,1	22	24	140	140	B-N14	B-W14	
B.MN	-1.23	GAB. BADAŃ	21,83	3,0	65,73	2,1	22	24	140	140	B-N14	B-W14	
B.MN	-1.24	REJESTRACJA	14,11	3,0	42,27	1,7	20	20	70	0	B-N6	z B.MN-1.73	
B.MN	-1.25	POCZTA PNEUMATYCZNA	1,25	3,0	3,72	-	-	-	-	-			
B.MN	-1.26	REJESTRACJA ZAPLECZE	13,51	3,0	41,37	1,7	20	20	60	70	B-N6	B-W6	
B.MN	-1.27	WC DAMSKI PRZEDSIONEK	3,56	3,0	11,04	-	-	-	-	-			
B.MN	-1.27A	WC DAMSKI WC	2,66	3,0	7,95	6,3	-	20	0	50	z B-MN_-1,73	B-WC1	
B.MN	-1.28	WC MĘSKI PRZEDSIONEK	3,05	3,0	9,27	-	-	-	-	-			
B.MN	-1.28A	WC MĘSKI WC	3,66	3,0	11,31	7,1	-	20	0	80	z B-MN_-1,73	B-WC1	
B.MN	-1.29	WC PACJENCI D.	3,78	3,0	15,06	3,3	-	20	0	50	z B-MN_-1,36A	B-WC1	
B.MN	-1.29A	WC DLA NIEPEŁNOSPRAWNYCH	4,74	3,0	15,09	6,6	-	20	0	100	z B-MN_-1,36A	B-WC1	
B.MN	-1.31	KABINA	3,96	3,0	11,88	2,5	-	20	0	30	z B-MN_-1,36	B-W3	
B.MN	-1.31A	KABINA	4,00	3,0	12,00	2,5	-	20	0	30	z B-MN_-1,36	B-W3	
B.MN	-1.31B	KABINA	2,19	3,0	6,51	4,6	-	20	0	30	z B-MN_-1,36	B-W3	
B.MN	-1.32	KABINA	2,20	3,0	6,51	4,6	-	20	0	30	z B-MN_-1,36	B-W3	
B.MN	-1.33	KABINA	4,03	3,0	11,88	2,5	-	20	0	30	z B-MN_-1,36	B-W3	
B.MN	-1.34	KABINA	3,90	3,0	11,52	2,6	-	20	0	30	z B-MN_-1,36	B-W3	

NR		POMIESZCZENIE	POW.	WYS.	KUB.	KROTNOŚĆ WYMIAN	T naw. zima	T w pom. zima	Vnaw	Vwyw	AHU naw	AHU wyw	UWAGI
[-]		[-]	[m <sup>2</sup> ]	[m]	[m <sup>3</sup> ]	[1/h]	[C]	[C]	[m <sup>3</sup> /h]	[m <sup>3</sup> /h]	[-]	[-]	[-]
B.MN	-1.35	KABINA	3,99	3,0	11,88	2,5	-	20	0	30	z B-MN_-1,36	B-W3	
B.MN	-1.36	POCZEKALNIA GORĄCA	19,82	3,0	59,34	3,5	24	20	210	0	B-N3	z kabin	
B.MN	-1.36A	PRZEDSIONEK	11,12	3,0	33,33	7,2	24	20	240	0	B-N3	z sąsiednich pom.	
B.MN	-1.36B	POCZEKALNIA ZIMNA	16,65	3,0	49,95	2,4	24	20	120	120	B-N3	B-W3	
B.MN	-1.37	PRZEDSIONEK	10,78	3,0	32,67	9,5	24	20	310	0	B-N3	do -1.64; -1.61	
B.MN	-1.38	APLIKACJA	9,78	3,0	30,51	6,2	24	20	170	190	B-N3	B-W3	filtr H11 na wyciągu
B.MN	-1.39	APLIKACJA	10,81	3,0	32,70	5,5	24	20	180	100	B-N3	B-W3	filtr H11 na wyciągu
B.MN	-1.40	ŁAZIENKA	2,53	3,0	7,74	12,9	-	24	0	100	z B-MN_-1,36A	B-WC11	
B.MN	-1.41	APLIKACJA	10,76	3,0	32,67	6,1	24	20	180	200	B-N8	B-W8	filtr H11 na wyciągu
B.MN	-1.42	APLIKACJA	10,42	3,0	31,59	6,0	24	20	170	190	B-N8	B-W8	filtr H11 na wyciągu
B.MN	-1.42A	ŁAZIENKA	4,38	3,0	13,11	7,6	-	24	0	100	z B-MN_-1.44	B-WC11	
B.MN	-1.43	POCZEKALNIA GORĄCA	15,16	3,0	45,39	4,8	24	20	220	220	B-N8	B-W8	
B.MN	-1.44	POCZEKALNIA GORĄCA	43,27	3,0	129,15	2,4	24	20	310	0	B-N8	do sąsiednich pom.	
B.MN	-1.45	PRZEDSIONEK	11,53	3,0	34,44	4,1	24	20	140	0	B-N8	z sąsiednich pom.	
B.MN	-1.46	WC PACJENCI D.	5,12	3,0	16,77	6,0	-	20	0	100	z B-MN_-1,44	B-WC11	
B.MN	-1.47	WC PACJENCI M.	7,20	3,0	21,72	4,6	-	20	0	100	z B-MN_-1,44	B-WC11	
B.MN	-1.48	WC PERSONELU DAMSKI PRZEDSIONEK	2,84	3,0	8,97	-	-	-	-	-			
B.MN	-1.48A	WC PERSONELU DAMSKI WC	2,15	3,0	6,45	7,8	-	20	0	50	z B-MN_-1,70	B-WC1	
B.MN	-1.49	WC PERSONELU MĘSKI PRZEDSIONEK	3,14	3,0	9,54	-	-	-	-	-			
B.MN	-1.49A	WC PERSONELU MĘSKI WC	5,74	3,0	17,22	4,6	-	20	0	80	z B-MN_-1,70	B-WC1	
B.MN	-1.50	GAMMA KAMERA	50,09	3,0	151,26	6,0	24	20	770	910	B-N8	B-W8	
B.MN	-1.51	UPS	13,33	3,0	39,99	1,3	24	20	50	50	B-N6	B-W6	
B.MN	-1.52	STEROWNIA	22,53	3,0	67,59	3,1	24	20	210	140	B-N8	B-W8	
B.MN	-1.53	SPEC / CT	48,78	3,0	147,24	6,0	24	20	750	890	B-N8	B-W8	
B.MN	-1.54	UPS	11,48	3	34,44	1,5	24	20	50	50	B-N6	B-W6	
B.MN	-1.55	PRZYGOTOWANIE RADIOFARM.	40,60	2,7	110,73	20,0	22	20	1990	2220	B-N2	B-W2	filtr H14 na nawiewie i na wyciągu
		komory do radiofarmaceutyków	-	-	-	-	-	-	-	250		B-WKR1	
		komory do radiofarmaceutyków	-	-	-	-	-	-	-	250		B-WKR2	
		komory do radiofarmaceutyków	-	-	-	-	-	-	-	250		B-WKR3	
		komory do radiofarmaceutyków	-	-	-	-	-	-	-	250		B-WKR4	
B.MN	-1.56	KONTROLA JAKOŚCI	20,92	3,0	52,17	16,3	22	20	850	800	B-N2	B-W2	filtr H11na nawiewie i na wyciągu
		ODCIĄG RADIOCHEMICZNY	-	-	-	-	-	-	-	800		B-WWR	
B.MN	-1.57	MAG. ŹRÓDEŁ PROM.	18,16	3,0	54,48	6,1	22	20	290	330	B-N2	B-WMI1	kłapa zwrotna na nawiewie, filtr H11 na wywiewie
B.MN	-1.58	MAG.ODP.PROM.	12,53	3,0	33,45	6,3	22	20	180	210	B-N2	B-WMI1	kłapa zwrotna na nawiewie, filtr H11 na na wywiewie
B.MN	-1.59	ŚLUZA DOZYMTRYCZNA	10,23	3,0	32,13	2,2	22	20	70	60	B-N2	B-W2	
B.MN	-1.61	PET / CT	65,96	3,0	198,81	6,0	24	20	990	1200	B-N3	B-W3	
B.MN	-1.62	UPS	7,20	3,0	21,60	2,3	24	20	50	50	B-N3	B-W3	
B.MN	-1.63	STEROWNIA	23,52	3,0	70,56	3,0	24	20	210	120	B-N3	B-W3	
B.MN	-1.64	PET / MRI	66,87	3,0	200,61	11,5	24	20	2000	2300	B-N3	B-W3	
		recyrkulacja	-	-	-	-	-	-	2560	2560			KLIMAKONWEKTOR KANAŁOWY

NR		POMIESZCZENIE	POW.	WYS.	KUB.	KROTNOŚĆ WYMIAN	T naw. zima	T w pom. zima	Vnaw	Vwyw	AHU naw	AHU wyw	UWAGI
[-]		[-]	[m <sup>2</sup> ]	[m]	[m <sup>3</sup> ]	[1/h]	[C]	[C]	[m <sup>3</sup> /h]	[m <sup>3</sup> /h]	[-]	[-]	[-]
B.MN	-1.65	PRACOWNIA RADIOIMMUNOLOGII	15,42	3,0	49,38	6,1	20	20	300	300	B-N6	B-W6	
B.MN	-1.66	UPS	17,64	3,0	52,92	2,1	24	20	90	110	B-N3	B-W3	
B.MN	-1.67	POM. TELETECHN.	5,89	3,0	19,59	2,0	20	16	40	40	B-N6	B-W6	
B.MN	-1.68	POM. ELEKTRYCZNE	4,86	3,0	16,17	2,5	20	16	40	40	B-N6	B-W6	
B.MN	-1.69	POM. PORZĄDKOWE	9,80	3,0	29,10	2,1	-	20	0	60	z B-MN_-1,73A	B-WC1	
B.MN	-1.70	KORYTARZ PERSONELU	71,63	3,0	214,89	2,0	20	20	440	220	B-N6	B-W6	
B.MN	-1.71	KORYTARZ TECHNICZNY	124,69	3,0	370,59	1,5	20	20	560	455	B-N6	B-W6	
B.MN	-1.72	KOMUNIKACJA	25,66	3,0	72,87	1,5	20	20	110	110	B-N6	B-W6	
B.MN	-1.73	KOMUNIKACJA	62,88	3,0	187,26	1,2	20	20	230	160	B-N6	B-W6	
B.MN	-1.73A	KOMUNIKACJA	33,03	3,0	95,10	1,6	20	20	150	90	B-N6	B-W6	
B.MN	-1,74	KOMUNIKACJA	98,59	3,0	294,03	1,2	20	20	350	200	B-N6	B-W6	
B.MN	-1.86	PRZEDSIONEK	7,51	3,0	27,24	2,2	22	20	60	0	B-N2	do pom. -1.58;-1.57	
B.MN	-1.87	ŚLUZA	4,82	3,0	16,53	10,9	22	20	180	100	B-N2	B-W2	
<b>POZIOM 0</b>													
B.DO	0.01	DYŻURKA LEKARSKA	22,60	3,0	67,80	1,6	22	20	110	110	B-N14	B-W14	
B.DO	0.01A	PRZEDSIONEK	7,01	2,7	18,93	5,3	22	20	100	0	B-N14	z B-DO_0.02	
B.DO	0.02	ŁAZIENKA	5,06	2,5	12,65	7,9	-	24	0	100	z B-DO_0.01A	B-WC1	
B.DO	0.03	WC PERSONELU MĘSKI	7,10	2,5	17,75	4,5	-	20	0	80	z B-DO_0.132	B-WC1	
B.DO	0.04	WC PERSONELU DAMSKI	4,83	2,5	12,08	4,1	-	20	0	50	z B-DO_0.132	B-WC1	
B.DO	0.05	MAGAZYN	12,17	2,7	32,86	1,8	22	20	60	60	B-N14	B-W14	
B.DO	0.06	POK. OPISÓW	16,04	3,0	48,12	1,7	22	20	80	80	B-N14	B-W14	
B.DO	0.07	POK. OPISÓW	15,86	3,0	47,58	1,7	22	20	80	80	B-N14	B-W14	
B.DO	0.08	POK. OPISÓW	15,75	3,0	47,25	1,7	22	20	80	80	B-N14	B-W14	
B.DO	0.09	MAG. BIEL. CZYSTEJ	14,37	2,7	38,80	2,3	22	20	90	0	B-N14	do B-DO_0.132A	
B.DO	0.10	ŁAZIENKA	4,09	2,5	10,23	9,8	-	24	0	100	z B-DO_0.11	B-WC1	
B.DO	0.10A	PRZEDSIONEK	4,14	2,5	10,35	-	-	-	-	-			
B.DO	0.11	POK. SOCJALNY	17,82	3,0	53,46	3,4	22	20	180	80	B-N14	B-WK1	
B.DO	0.12	POM. TECHNICZNE	11,99	3,0	35,97	1,7	-	16	0	60	z pom. B-EN_0.132A	B-W6	
B.DO	0.13	PRAC. REZONANSU	38,53	3,0	115,59	4,1	22	20	440	470	B-N1	B-W1	
		KLATKA Faradaya	9,00	3,0	27,00	12,6	-	-	320	340	B-N1	B-W1	KLIMAKONWEKTOR KANAŁOWY
B.DO	0.14	przygotowanie pacjenta	15,36	2,7	41,47	1,7	22	24	70	70	B-N1	B-W1	
B.DO	0.17	PRACOWNIA DENSYTOMETRII	16,30	3,0	48,90	2,0	24	20	90	100	B-N7	B-W7	
B.DO	0.18	PRACOWNIA RTG STM PANORAMA	14,89	3,0	44,67	2,2	24	20	90	100	B-N7	B-W7	
B.DO	0.19	PRACOWNIA RTG STM PUNKTOWE	13,40	3,0	40,20	2,2	24	20	80	90	B-N7	B-W7	
B.DO	0.20	WC PACJENCI M.	3,49	2,5	8,73	9,2	-	20	0	80	z B-DO_0.133	B-WC1	
B.DO	0.20A	WC PACJENCI MĘSKI/WC	5,13	2,5	12,83	-	-	-	-	-	-	-	
B.DO	0.21	WC PACJENCI D.	3,17	2,5	7,93	6,3	-	20	0	50	z B-DO_0,133	B-WC1	
B.DO	0.21A	WC PACJENCI DAMSKI/WC	2,40	2,5	6,00	-	-	-	-	-	-	-	
B.DO	0.24	WC DAMSKI / DLA NIEPEŁNOSPRAWNYCH	4,79	2,5	11,98	8,4	-	20	0	100	z B-DO_0.133	B-WC1	
B.DO	0.25	GABINET USG	9,73	3,0	29,19	2,7	20	24	80	0	B-N9	z B-DO_0.27	
B.DO	0.26	GABINET USG	10,51	3,0	31,53	2,9	20	24	90	90	B-N9	B-W9	
B.DO	0.27	WC	3,44	2,5	8,60	9,3	-	20	0	80	z B-DO_0.25	B-WC1	

NR		POMIESZCZENIE	POW.	WYS.	KUB.	KROTNOŚĆ WYMIAN	T naw. zima	T w pom. zima	Vnaw	Vwyw	AHU naw	AHU wyw	UWAGI
[-]		[-]	[m <sup>2</sup> ]	[m]	[m <sup>3</sup> ]	[1/h]	[C]	[C]	[m <sup>3</sup> /h]	[m <sup>3</sup> /h]	[-]	[-]	[-]
B.DO	0.29	POKÓJ REZYDENTÓW	30,92	3,0	92,76	1,6	22	20	150	150	B-N14	B-W14	
B.DO	0.30	POK. OPISÓW	24,31	3,0	72,93	1,5	22	20	110	110	B-N14	B-W14	
B.DO	0.31	POK. OPISÓW	24,41	3,0	73,23	1,5	22	20	110	110	B-N14	B-W14	
B.DO	0.32	POK. OPISÓW	24,25	3,0	72,75	1,5	22	20	110	110	B-N14	B-W14	
B.DO	0.33	MAG. BIEL. BRUDNEJ	5,01	2,7	13,53	6,7	-	20	0	90	z B-DO_0.132	B-WB1	
B.DO	0.34	MAGAZYN BIEL. CZYSTEJ	10,31	2,5	25,26	2,8	20	20	70	0	B-N6	DO B-DO_0.132	
B.DO	0.35	STEROWNIA	29,01	2,7	78,33	1,8	24	20	140	140	B-N7	B-W7	
B.DO	0.36	GAB. RTG	32,76	2,7	88,45	5,7	24	20	400	500	B-N7	B-W7	
B.DO	0.37	WC	2,69	2,5	6,73	7,4	-	20	0	50	z B-DO_0.36	B-WC1	
B.DO	0.38	KABINA	4,43	2,5	11,08	4,5	24	24	50	0	B-N7		
B.DO	0.39	KABINA	3,38	2,5	8,45	5,9	24	24	50	0	B-N7		
B.DO	0.40	GAB. RTG	33,06	2,7	89,26	5,6	24	20	400	500	B-N7	B-W7	
B.DO	0.41	KABINA	4,01	2,5	10,03	5,0	24	24	50	0	B-N7		
B.DO	0.42	KABINA	3,19	2,5	7,98	6,3	24	24	50	0	B-N7		
B.DO	0.43	WC	2,83	2,5	7,08	7,1	-	20	0	50	z B-DO_0.40	B-WC1	
B.DO	0.44	STEROWNIA	23,78	2,7	64,21	1,7	24	20	110	110	B-N7	B-W7	
B.DO	0.45	GAB. RTG	32,68	2,7	88,24	5,7	24	20	400	500	B-N7	B-W7	
B.DO	0.46	KABINA	4,43	2,5	11,08	4,5	24	24	50	0	B-N7	B-W7	
B.DO	0.47	KABINA	3,18	2,5	7,95	6,3	24	24	50	0	B-N7	B-W7	
B.DO	0.48	WC	2,99	2,5	7,48	6,7	-	20	0	50	z B-DO_0,45	B-WC1	
B.DO	0.49	POM. TECHNICZNE	4,91	3,0	14,73	2,0	-	20	0	30	z B-DO_0.132A	B-W6	
B.DO	0.50	GAB. RTG	32,54	2,7	87,86	5,7	24	20	400	500	B-N7	B-W7	
B.DO	0.51	KABINA	4,43	2,5	11,08	4,5	24	24	50	0	B-N7	B-W7	
B.DO	0.52	KABINA	3,18	2,5	7,95	6,3	24	24	50	0	B-N7	B-W7	
B.DO	0.53	WC	3,30	2,5	8,25	6,1	-	20	0	50	z B-DO_0,45	B-WC1	
B.DO	0.54	ŁAZIENKA	3,44	2,5	8,60	11,6	-	24	0	100	z B-DO_0.55	B-WC1	
B.DO	0.55	GAB. KIEROWNIKA	10,92	3	32,76	3,1	22	20	100	0	B-N14	do B-DO_0.54	
B.DO	0.56	POM. TELETECHNICZNE	7,65	3	22,95	1,7	20	16	40	40	B-N6	B-W6	
B.DO	0.57	POM. ELEKTRYCZNE	4,00	3	12,00	1,7	20	16	20	20	B-N6	B-W6	
B.DO	0.58	GABINET USG	12,62	2,7	34,07	2,6	20	24	90	90	B-N9	B-W9	
B.DO	0.59	GABINET USG	12,43	2,7	33,56	2,7	20	24	90	90	B-N9	B-W9	
B.DO	0.60	BIOPSIJA	13,76	3	41,28	2,2	20	24	90	80	B-N9	B-W9	
B.DO	0.61	BIOPSIJA	15,96	3	47,88	2,1	20	24	100	90	B-N9	B-W9	
B.DO	0.62	GAB. MAMMOGRAFII	15,68	3	47,04	3,3	20	24	155	0	B-N9	z B-DO_0.62A	
B.DO	0.62A	POM. PRZYGOTOWANIA	3,62	2,7	9,77	15,9	-	24	0	155	z B-DO_0.62	B-W9	
B.DO	0.63	WC PACJENTÓW	4,69	2,5	11,73	8,5	-	20	0	100	z B-DO_0.67	B-WC1	
B.DO	0.64	WC PACJENTÓW	4,97	2,5	12,43	8,0	-	20	0	100	z B-DO_0.67	B-WC1	
B.DO	0.65	POK. OPISÓW	8,96	3	26,88	2,2	22	20	60	60	B-N14	B-W14	
B.DO	0.66	DOZÓR	5,83	2,5	14,58	2,1	20	20	30	30	B-N6	B-W6	
B.DO	0.67	KOMUNIKACJA	72,52	2,5	181,30	2,9	20	20	520	320	B-N6	B-W6	
B.DO	0.68	GAB. MAMMOGRAFII	18,46	3	55,38	3,3	20	24	180	100	B-N9	B-W9	
B.DO	0.68A	POM. PRZYGOTOWANIA	3,28	3	9,84	8,1	-	24	0	80	z B-DO_0.68	B-W9	
B.DO	0.69	POK. LEKARZY	18,96	3	56,88	1,6	22	20	90	90	B-N14	B-W14	
B.DO	0.70	POM. BIUROWE	19,50	3	58,50	1,5	22	20	90	90	B-N14	B-W14	

NR		POMIESZCZENIE	POW.	WYS.	KUB.	KROTNOŚĆ WYMIAN	T naw. zima	T w pom. zima	Vnaw	Vwyw	AHU naw	AHU wyw	UWAGI
[-]		[-]	[m <sup>2</sup> ]	[m]	[m <sup>3</sup> ]	[1/h]	[C]	[C]	[m <sup>3</sup> /h]	[m <sup>3</sup> /h]	[-]	[-]	[-]
B.DO	0.71	POM. BIUROWE	20,36	3	61,08	1,6	22	20	100	100	B-N14	B-W14	
B.DO	0.72	SEKRETARIAT	19,47	3	58,41	1,5	22	20	90	90	B-N14	B-W14	
B.DO	0.73	POCZEKALNIA	18,72	3	56,16	7,1	20	20	400	130	B-N6	B-W6	
B.DO	0.74	POCZEKALNIA	19,35	3	58,05	6,9	20	20	400	250	B-N6	B-W6	
B.DO	0.75	NADZÓR	9,41	3	28,23	1,8	20	20	50	0	B-N6	do B-DO_0.134	
B.DO	0.76	POM. PRZYG. PACJENTA	11,12	3	33,36	2,1	22	22	70	70	B-N5	B-W5	
B.DO	0.77	WC PACJENCI M.	3,97	2,5	9,93	8,1	-	20	0	80	z B-DO_0,134A	B-WC1	
B.DO	0.77A	WC PACJENCI M. / WC	6,50	2,5	16,25	-	-	20	-	-	-	-	
B.DO	0.78	WC PERSONELU DAMSKI	3,15	2,5	7,88	6,3	-	20	0	50	z B-DO_0,134A	B-WC1	
B.DO	0.78A	WC PERSONELU MĘSKI	4,09	2,5	10,23	7,8	-	20	0	80	z B-DO_0,134A	B-WC1	
B.DO	0.78B	WC PERSONELU DAMSKI	2,21	2,5	5,53	-	-	-	-	-	-	-	
B.DO	0.78C	WC PERSONELU MĘSKI	6,51	2,5	16,28	-	-	-	-	-	-	-	
B.DO	0.79	WC DAMSKI / DLA NIEPEŁNOSPRAWNYCH	6,04	2,5	15,10	6,6	-	20	0	100	z B-DO_0,134A	B-WC1	
B.DO	0.80	ARCHIWUM	6,79	2,7	18,33	1,6	-	20	0	30	z B-DO_0,134A	B-W6	
B.DO	0.81	DYŻURKA PERSONELU	14,51	3,0	43,53	2,8	22	20	120	120	B-N14	B-W14	
B.DO	0.82	ŁAZIENKA	3,30	2,5	8,25	12,1	-	24	0	100	z B-DO_0,136 i83	B-WC1	
B.DO	0.83	PRZEDSIONEK	5,58	2,7	15,07	3,3	22	20	50	0	B-N14	do B-DO_0,82	
B.DO	0.84	SALA SEMINARYJNA	39,23	3,0	117,69	6,6	20	20	780	780	E-N2	E-W2	system z budynku G+E
B.DO	0.85	DOZÓR	10,66	2,5	26,65	3,4	20	20	90	0	B-N6	z B-DO_0,134A	
B.DO	0.86	POCZTA PNEUMATYCZNA	0,65	-	-	-	-	-	-	-	-	-	
B.DO	0.87	ZAPLECZE	4,83	2,5	12,08	5,0	-	20	0	60	z B-DO_0,134A	B-W6	
B.DO	0.88	ŁAZIENKA	4,74	2,5	11,85	9,3	-	24	0	110	z B-DO_0,90	B-WC1	
B.DO	0.89	PRZEDSIONEK	5,75	2,7	15,53	2,6	-	20	0	40	z B-DO_0,90	B-W14	
B.DO	0.90	DYŻURKA PERSONELU	18,43	3,0	55,29	2,7	22	20	150	0	B-N14	do 88 i 89	
B.DO	0.91	PRZEDSIONEK	6,24	2,7	16,85	2,4	22	20	0	40	z B-DO_0,93	B-W14	
B.DO	0.92	ŁAZIENKA	5,64	2,5	14,10	7,8	-	24	0	110	z B-DO_0,93	B-WC1	
B.DO	0.93	DYŻURKA PERSONELU	17,28	3,0	51,84	2,9	22	20	150	0	B-N14	do 91 i 92	
B.DO	0.94	POM. ELEKTRYCZNE	5,92	3,0	17,76	1,7	20	16	30	30	B-N6	B-W6	
B.DO	0.95	POM. TELETECHNICZNE	6,32	3,0	18,96	1,6	20	16	30	30	B-N6	B-W6	
B.DO	0.97	WC	4,77	2,7	12,88	7,8	-	20	0	100	z B-DO_0,98	B-WC1	
B.DO	0.98	POM. PRZYG. PACJENTA	31,37	2,7	84,70	2,1	22	22	180	80	B-N5	B-W5	
B.DO	0.99	STEROWNIA	18,37	2,7	49,60	1,8	22	20	80	90	B-N5	B-W5	
B.DO	0.100	WC	4,68	2,5	11,70	8,5	-	20	0	100	z B-DO_0,101	B-WC1	
B.DO	0.101	POM. PRZYG. PACJENTA	30,13	2,7	81,35	2,5	22	22	200	0	B-N5	B-W5	
B.DO	0.102	KABINA	4,01	2,5	10,03	5,0	-	24	0	50	z B-DO_0,101	B-W5	
B.DO	0.103	KABINA	4,12	2,5	10,30	4,9	-	24	0	50	z B-DO_0,101	B-W5	
B.DO	0.104	POM. PRZYG. PACJENTA	29,95	2,7	80,87	2,6	22	22	210	0	B-N5	B-W5	
B.DO	0.104A	WC	5,02	2,5	12,55	8,0	-	20	0	100	z B-DO_0,104	B-WC1	
FIND	0.104B	POM. PRZYG. PACJENTA	31,12	2,7	84,02	3,6	22	22	300	0	B-N5	B-W5	
B.DO	0.105	KABINA	4,01	2,5	10,03	5,0	-	24	0	50	z B-DO_0,104	B-W5	
B.DO	0.106	KABINA	3,76	2,5	9,40	5,3	-	24	0	50	z B-DO_0,104	B-W5	
B.DO	0.107	STEROWNIA	9,07	2,7	24,49	3,7	22	20	80	90	B-N5	B-W5	
B.DO	0.107A	STEROWNIA	7,89	2,7	21,30	3,3	22	20	60	70	B-N5	B-W5	
B.DO	0.108	KABINA	4,05	2,5	10,13	4,9	-	24	0	50	z B-DO_0,104B	B-W5	

NR		POMIESZCZENIE	POW.	WYS.	KUB.	KROTNOŚĆ WYMIAN	T naw. zima	T w pom. zima	Vnaw	Vwyw	AHU naw	AHU wyw	UWAGI
[-]		[-]	[m <sup>2</sup> ]	[m]	[m <sup>3</sup> ]	[1/h]	[C]	[C]	[m <sup>3</sup> /h]	[m <sup>3</sup> /h]	[-]	[-]	[-]
B.DO	0.109	KABINA	3,98	2,5	9,95	5,0	-	24	0	50	z B-DO_0,104B	B-W5	
B.DO	0.111	GAB. TOMOGRAFII KOMPUTER.	36,01	3,0	108,03	4,8	22	22	450	520	B-N5	B-W5	
B.DO	0.112	KABINA	5,19	2,5	12,98	3,9	-	24	0	50	z B-DO_0,113A	B-W5	
B.DO	0.113	KABINA	4,97	2,5	12,43	4,0	-	24	0	50	z B-DO_0,113A	B-W5	
B.DO	0.113A	POM. PRZYG. PACJENTA	27,69	2,7	74,76	4,8	22	22	360	0	B-N5	B-W5	
B.DO	0.114	STEROWNIA	16,88	2,7	45,58	2,4	22	20	90	110	B-N5	B-W5	
B.DO	0.115	GAB. TOMOGRAFII KOMPUTER.	35,48	3,0	106,44	4,7	22	22	430	500	B-N5	B-W5	
B.DO	0.117	WC	6,41	2,5	16,03	6,2	-	20	0	100	z B-DO_0,113A	B-WC1	
B.DO	0.118	GAB. TOMOGRAFII KOMPUTER.	51,38	3,0	154,14	4,8	22	22	650	740	B-N5	B-W5	
B.DO	0.119	WC	4,71	2,5	11,78	8,5	-	20	0	100	z B-DO_0,104B	B-WC1	
B.DO	0.120	POM. TECHNICZNE	10,03	3,0	30,09	2,3	20	20	60	70	B-N1	B-W1	
B.DO	0.121	GABINET REZONANSU MAGNET.	50,89	3,0	152,67	13,5	21	18	2060	2060	B-N1	B-W1	
	0.121	recyrkulacja	-	-	-	-	-	-	1860	1860			KLIMAKONWEKTOR KANAŁOWY
	0.121	QUENCH RURA	-	-	-	-	-	-	-	-		B-WH1	
B.DO	0.122	POM. TECHNICZNE	10,58	3,0	31,74	2,2	22	20	60	70	B-N1	B-W1	
B.DO	0.123	POM. TECHNICZNE rezonansu	10,10	3,0	30,30	2,3	22	20	60	70	B-N1	B-W1	
B.DO	0.124	GABINET REZONANSU MAGNET.	50,33	3,0	150,99	13,2	21	18	2000	2000	B-N1	B-W1	
	0.124	recyrkulacja	-	-	-	-	-	-	1700	1700			KLIMAKONWEKTOR KANAŁOWY
	0.124	QUENCH RURA	-	-	-	-	-	-	-	-		B-WH3	
B.DO	0.126	POM. TECHNICZNE	11,16	3,0	33,48	2,4	22	20	70	80	B-N1	B-W1	
B.DO	0.127	POM. PORZĄDKOWE	5,41	2,5	13,53	3,0	-	20	0	40	z B-DO_0,135	B-WC1	
B.DO	0.128	GABINET REZONANSU MAGNET.	40,26	3,0	120,78	16,6	21	18	2000	2000	B-N1	B-W1	
	0.128	recyrkulacja	-	-	-	-	-	-	1730	1730			KLIMAKONWEKTOR KANAŁOWY
	0.128	QUENCH RURA	-	-	-	-	-	-	-	-		B-WH2	
B.DO	0.129	POM. TECHNICZNE	9,91	3,0	29,73	2,0	22	20	50	60	B-N1	B-W1	
B.DO	0.130	KOMUNIKACJA	21,02	3,0	63,06	-	-	-	-	-			
B.DO	0.132	KOMUNIKACJA	71,64	2,5	179,10	1,8	20	20	320	170	B-N6	B-W6	
B.DO	0.132A	KOMUNIKACJA	64,24	2,5	160,60	1,8	20	20	290	290	B-N6	B-W6	
B.DO	0.133	KOMUNIKACJA	123,07	2,5	307,68	2,5	20	20	780	280	B-N6	B-W6	
		RIT	-	-	0,00	-	-	-	-	30	Z POM. B-EN_0.133	B-W6	
B.DO	0.134	KOMUNIKACJA	93,21	2,5	233,03	2,0	20	20	0	470	z poczek 73,75	B-W6	
B.DO	0.134A	KOMUNIKACJA	94,46	2,5	236,15	2,2	20	20	520	210	B-N6	B-W6	
B.DO	0.135	KOMUNIKACJA	87,42	2,5	218,55	2,2	20	20	480	390	B-N6	B-W6	
B.DO	0.136	KOMUNIKACJA	30,85	2,5	77,13	1,8	20	20	140	90	B-N6	B-W6	
B.DO	0.137	KOMUNIKACJA	15,59	2,5	38,98	2,1	20	20	80	80	B-N6	B-W6	
B.DO	0.138	KOMUNIKACJA	8,23	2,5	20,58	1,9	20	20	40	40	B-N6	B-W6	
B.DO	0.139	WIATROLAP	15,12	3,0	45,36	-	-	-	-	-			
B.KL1		KLATKA SCHOD.	31,93	3,0	95,79	-	-	-	-	-			
B.KL2		KLATKA SCHOD.	33,11	3,0	99,33	-	-	-	-	-			
<b>POZIOM 0</b>													
B.AN	1.01	WC PERSONELU MĘSKI	2,46	2,5	6,15	13,0	-	20	0	80	z B-AN_1.10	B-WC1	
B.AN	1.01A	WC PERSONELU MĘSKI WC	4,25	2,5	10,63	-	-	20	-	-			
B.AN	1.02	WC PERSONELU DAMSKI	2,67	2,5	6,68	7,5	-	20	0	50	z B-AN_1.10	B-WC1	

NR		POMIESZCZENIE	POW.	WYS.	KUB.	KROTNOŚĆ WYMIAN	T naw. zima	T w pom. zima	Vnaw	Vwyw	AHU naw	AHU wyw	UWAGI
[-]		[-]	[m <sup>2</sup> ]	[m]	[m <sup>3</sup> ]	[1/h]	[C]	[C]	[m <sup>3</sup> /h]	[m <sup>3</sup> /h]	[-]	[-]	[-]
B.AN	1.02A	WC PERSONELU DAMSKI WC	2,10	2,5	5,25		-	20					
B.AN	1.03	POM. ELEKTRYCZNE	7,63	3,0	22,89	1,7	20	16	40	40	B-N6	B-W6	
B.AN	1.04	POM. TELETECHNICZNE	3,99	3,0	11,97	3,3	20	16	40	40	B-N6	B-W6	
B.AN	1.05	POM. BIUROWE / SEKRETARIAT	23,01	3,0	69,03	1,6	22	20	110	110	B-N14	B-W14	
B.AN	1.05A	POM. BIUROWE / GAB. KIEROWNIKA	13,18	3,0	39,54	1,5	22	20	60	0	B-N14	do B-AN_1.05B	
B.AN	1.05B	WC	2,72	2,5	6,80	8,8	-	20	0	60	z B-AN_1.05A	B-WC1	
B.AN	1.06	POM. BIUROWE	11,13	3,0	33,39	1,8	22	20	60	60	B-N14	B-W14	
B.AN	1.07	SALA SEMINARYJNA	46,10	3,0	138,30	5,6	20	20	780	780	B-N13	B-W13	REGULATOR - STEROWANIE WG. POZIOMU CO2
B.AN	1.08	SALA SEMINARYJNA	45,48	3,0	136,44	5,7	20	20	780	780	B-N13	B-W13	REGULATOR - STEROWANIE WG. POZIOMU CO2
B.AN	1.10	KOMUNIKACJA	61,38	2,5	153,45	1,8	20	20	280	170	B-N6	B-W6	
B.AN	1.11	POM. WSTĘPNEGO MYCIA SPRZĘTU I NAJ	9,74	2,7	26,30	4,6	20	20	110	120	B-N6	B-WZ1	
B.AN	1.12	POK. OPISÓW	19,76	3,0	59,28	2,0	22	20	120	120	B-N14	B-W14	
B.AN	1.13	POK. LEKARZY	12,96	3,0	38,88	2,6	22	20	100	0	B-N14	B-W14	
B.AN	1.14	ŁAZIENKA	3,67	2,5	9,18	10,9	-	24	0	100	z B-AN_1.13	B-WC1	
B.AN	1.15	POM. TECHNICZNE	16,98	3,0	50,94	2,2	20	20	110	110	B-N6	B-W6	
B.AN	1.16	STEROWNIA	10,46	2,7	28,24	8,1	24	20	70	230	B-N16	B-W16	
B.AN	1.16A	STEROWNIA	10,93	2,7	29,51	10,7	24	20	90	315	B-N16	B-W16	
B.AN	1.17	GAB. ANGIOGRAFII	64,87	3,0	194,61	11,4	24	20	2210	1760	B-N16	B-W16	filtr H11 na nawiewie, nagr. Kanatowa
B.AN	1.18	POM. PRZYG. LEKARZY	6,13	2,7	16,55	8,2	24	24	150	130	B-N16	B-W16	nagr. kanatowa
B.AN	1.18A	POM. PRZYG. LEKARZY	4,65	2,7	12,56	7,9	24	24	110	90	B-N16	B-W16	nagr. kanatowa
B.AN	1.19	GAB. ANGIOGRAFII	54,28	3,0	162,84	9,8	24	20	1600	1280	B-N16	B-W16	filtr H11 na nawiewie, nagr. Kanatowa
B.AN	1.20	POM. TECHNICZNE	9,03	3,0	27,09	2,2	-	20	0	60	z B-AN_1.31	B-W6	
B.AN	1.21A	WC PERSONELU DAMSKI	2,21	2,5	5,53	9,0	-	20	0	50	z B-AN_1.33	B-WC1	
B.AN	1.21	WC PERSONELU DAMSKI WC	2,03	2,5	5,08	-	-	-	-	-	z B-AN_1.33	B-WC1	
B.AN	1.22A	WC PERSONELU MĘSKI	4,86	2,5	12,15	6,6	-	20	0	80	z B-AN_1.33	B-WC1	
B.AN	1.22	WC PERSONELU MĘSKI WC	2,04	2,5	5,10	-	-	-	-	-	z B-AN_1.33	B-WC1	
B.AN	1.23	POM. PORZĄDKOWE	1,81	3,0	5,43	3,7	-	16	0	20	z B-AN_1.33	B-WC1	
B.AN	1.24	MAG. BIEL. CZYSTEJ	2,29	2,5	5,73	4,4	20	20	30	0	B-N6	do B-AN_1.35	
B.AN	1.26	POK. TECHNIKÓW I PIELĘGNIAREK	21,87	3,0	65,61	1,8	22	20	120	120	B-N14	B-W14	
B.AN	1.27	POM. PRZYG. PACJENTA	23,08	2,7	62,32	7,5	24	24	520	400	B-N16	B-W16	nagr. kanatowa
B.AN	1.28	POK. PIELĘGNIAREK	10,52	3,0	31,56	3,2	24	20	100	120	B-N15	B-W15	
B.AN	1.28A	ŁAZIENKA	5,91	2,5	14,78	4,1	-	24	0	60	z B-AN_1.27	B-WC1	
B.AN	1.29	BRUDOWNIK	3,97	2,7	10,72	8,4	-	16	0	100	z B-AN_1.35	B-WB1	
B.AN	1.30	POM. WYBUDZEŃ	46,18	3,0	138,54	10,0	24	24	1380	1240	B-N15	B-W15	
B.AN	1.31	KOMUNIKACJA	35,29	2,5	88,23	1,3	20	20	140	80	B-N6	B-W6	
B.AN	1.32	POK. PERSONELU	16,13	3,0	48,39	2,5	20	20	120	120	B-N6	B-W6	
B.AN	1.33	KOMUNIKACJA	21,16	2,5	52,90	1,9	20	20	120	0	B-N6	do B-AN_1.21,22,23,11	
B.AN	1.34	ŚLUZA UMYW.-FARTUCH.	5,74	2,5	14,35	3,5	20	20	60	0	B-N6	do pom. 1.33,10	
B.AN	1.35	KOMUNIKACJA	40,55	2,5	101,38	2,4	20	20	180	290	B-N6	B-W6	
			-	-	-	-	-	-	-	385	B-N6	B-W16	
B.HD	1.36	POK. PERSONELU	12,22	3,0	36,66	3,3	22	20	120	0	B-N14	do B-HD_1.37	

NR		POMIESZCZENIE	POW.	WYS.	KUB.	KROTNOŚĆ WYMIAN	T naw. zima	T w pom. zima	Vnaw	Vwyw	AHU naw	AHU wyw	UWAGI
[-]		[-]	[m <sup>2</sup> ]	[m]	[m <sup>3</sup> ]	[1/h]	[C]	[C]	[m <sup>3</sup> /h]	[m <sup>3</sup> /h]	[-]	[-]	[-]
B.HD	1.37	ŁAZIENKA	3,71	2,5	9,28	12,9	-	24	0	120	z B-HD_1,36	B-WC1	
B.HD	1.38	POK. LEKARZY	10,40	2,7	28,08	1,9	22	20	60	0	B-N14	B-W14	
B.HD	1.39	WC	2,16	2,5	5,40	11,1	-	20	0	60	z B-HD_1.38	B-WC1	
B.HD	1.40	POK. OPISÓW	17,29	3,0	51,87	1,7	22	20	90	90	B-N14	B-W14	
B.HD	1.42	GAB. KIEROWNIKA	9,20	3,0	27,60	3,6	22	20	100	0	B-N14	do pom. B-HD_1.43	
B.HD	1.43	ŁAZIENKA	3,25	2,5	8,13	12,3	-	20	0	100	z B-HD_1,42	B-WC1	
B.HD	1.44	SEKRETARIAT	10,51	3,0	31,53	2,2	22	20	70	70	B-N14	B-W14	
B.HD	1.45	GAB. KONSULTACYJNY	10,85	3,0	32,55	2,2	22	24	70	70	B-N14	B-W14	
B.HD	1.46	REJESTRACJA	9,92	3,0	29,76	1,7	20	20	50	0	B-N14	do B-HD_1.78	
B.HD	1.47	ZAPLECZE	7,01	2,5	17,53	1,9	20	20	40	40	B-N14	B-W14	
B.HD	1.48	WC PACJENCI M.	2,68	2,5	6,70	-	-	-	-	-	B-N14	B-W14	
B.HD	1.48A	WC PACJENCI M. WC	5,18	2,5	12,95	11,9	-	20	0	80	z B-HD_1.78	B-WC1	
B.HD	1.49	WC DLA OS. NIEPEŁNOSPRAWNYCH	4,62	2,5	11,55	4,3	-	20	0	50	z B-HD_1.78	B-WC1	
B.HD	1.50	POM. TELETECHNICZNE	5,17	3,0	15,51	1,9	20	16	30	30	B-N6	B-W6	
B.HD	1.51	POM. ELEKTRYCZNE	4,99	3,0	14,97	2,0	20	16	30	30	B-N6	B-W6	
B.HD	1.51A	POM. MYCIA	6,38	2,7	17,23	4,2	-	20	0	80	z B-HD_1.56	B-WC1	
B.HD	1.52	WC PERSONELU MĘSKI	3,50	2,5	8,75	9,1	-	20	0	80	z B-HD_1.78	B-WC1	
B.HD	1.52A	WC PERSONELU MĘSKI WC	4,01	2,5	10,03	-	-	-	-	-	z B-HD_1.78	B-WC1	
B.HD	1.53	WC PERSONELU DAMSKI	2,71	2,5	6,78	7,4	-	20	0	50	z B-HD_1.80	B-WC1	
B.HD	1.53A	WC PERSONELU DAMSKI WC	1,82	2,5	4,55	-	-	-	-	-	z B-HD_1.80	B-WC1	
B.HD	1.54	POM. TECHNICZNE	10,47	3,0	31,41	2,2	-	20	0	70	z B-HD_1.80	B-W6	
B.HD	1.55	STEROWNIA	10,15	2,7	27,41	6,2	24	20	70	190	B-N11	B-W11	
B.HD	1.55A	STEROWNIA	11,89	2,7	32,10	12,3	26	20	80	440	B-N12	B-W12	
B.HD	1.56	SALA ZABIEGOWA HYBRYDOWA	65,25	3,0	195,75	20,1	26	20	3940	3150	B-N12	B-W12	strop laminarny filtr H13
B.HD	1.57	MAGAZYN	7,12	2,7	19,22	3,3	-	20	0	70	z B-HD_1.56	B-W12	
B.HD	1.58	POM. PRZYG. LEKARZY	5,17	2,7	13,96	11,0	-	24	170	150	B-N12	B-W12	nagrz. kanatowa
B.HD	1.59	POM. TECHNICZNE	20,40	3,0	61,20	2,1	20	20	130	130	B-N6	B-W6	
B.HD	1.60	SALA ZABIEGOWA HEMODYNAMIKI	43,35	3,0	130,05	10,1	24	24	1320	1060	B-N11	B-W11	filtr H13 na nawiewie, nagrz. Kanatowa
B.HD	1.61	POM. PRZYG. LEKARZY	4,69	3,0	14,07	10,0	24	24	140	120	B-N11	B-W11	nagrz. kanatowa
B.HD	1.61A	POM. PRZYG. LEKARZY	4,28	3,0	12,84	10,1	24	24	130	110	B-N11	B-W11	nagrz. kanatowa
B.HD	1.62	SALA ZABIEGOWA HEMODYNAMIKI	45,11	3,0	135,33	10,1	24	24	1370	1090	B-N11	B-W11	filtr H13 na nawiewie, nagrz. Kanatowa
B.HD	1.63	STEROWNIA	16,50	3,0	49,50	4,6	24	20	100	230	B-N11	B-W11	
B.HD	1.65	BRUDOWNIK	4,07	3,0	12,21	7,4	-	20	0	90	z B-HD_1.81	B-WB1	
B.HD	1.66	POM. PRZYG. PACJENTA	40,75	2,7	110,03	6,3	24	24	770	680	B-N11	B-W11	nagrz. kanatowa
B.HD	1.66A	ŁAZIENKA	5,32	2,5	13,30	3,1	-	24	0	50	z B-HD_1.66	B-WC1	
B.HD	1.67	POK. PIEŁĘGNIAREK	12,11	3,0	36,33	3,3	24	20	100	120	B-N15	B-W15	
B.HD	1.68	MAG. BIEL. CZYSTEJ	1,70	3,0	5,10	5,9	20	20	30	0	B-N6	do B-HD_1.81	
B.HD	1.70	SALA WYBUDZEŃ	43,29	3,0	129,87	10,0	24	24	1300	1170	B-N15	B-W15	
B.HD	1.71	SZATNIA CZYSTA	13,94	2,7	37,64	4,1	24	24	170	0	B-N15	do B-HD_1.72	
B.HD	1.72	UMYWALNIA	14,45	2,5	36,13	5,5	-	24	0	200	z B-HD_1.71 i 73	B-WC1	
B.HD	1.72A	UMYWALNIA / WC	1,49	2,5	3,73	-	-	-	-	-	z B-HD_1.71 i 73	B-WC1	
B.HD	1.73	SZATNIA BRUDNA	14,79	2,7	39,93	4,5	20	24	120	180	B-N6	B-W6	
B.HD	1.74	SZATNIA CZYSTA	7,01	2,7	18,93	7,9	24	24	150	0	B-N15	do B-HD_1.75	



NR		POMIESZCZENIE	POW.	WYS.	KUB.	KROTNOŚĆ WYMIAN	T naw. zima	T w pom. zima	Vnaw	Vwyw	AHU naw	AHU wyw	UWAGI
[-]		[-]	[m <sup>2</sup> ]	[m]	[m <sup>3</sup> ]	[1/h]	[C]	[C]	[m <sup>3</sup> /h]	[m <sup>3</sup> /h]	[-]	[-]	[-]
B.HD	1.75	UMYWALNIA	11,80	2,5	29,50	6,8	-	24	0	200	z B-HD_1,74	B-WC1	
B.HD	1.75A	UMYWALNIA / WC	1,40	2,5	3,50	-	-	-	-	-	z B-HD_1,74	B-WC1	
B.HD	1.76	SZATNIA BRUDNA	6,62	3,0	19,86	4,5	20	24	50	90	B-N6	B-W6	
B.HD	1.77	SALA SEMINARYJNA	35,77	3,0	107,31	7,5	20	20	810	810	E-N2	E-W2	system z budynku G+E
B.HD	1.78	KOMUNIKACJA	114,52	2,5	286,30	1,8	20	20	610	270	B-N6	B-W6	
B.HD	1.80	KOMUNIKACJA	38,88	2,3	89,42	1,8	20	20	160	90	B-N6	B-W6	
B.HD	1.81	KOMUNIKACJA	50,18	2,5	125,45	1,9	20	20	230	280	B-N6	B-W6	
			-	-	-	-	-	-	-	350		B-W11	
			-	-	-	-	-	-	-	380		B-W12	
B.HD	1.82	ŚLUZA UMYW.-FARTUCH.	9,41	2,5	23,53	3,5	20	20	100	0	B-N6	do B-HD_1.78	
B.KL1		KLATKA SCHOD.	32,44	2,7	87,60	-	-	-	-	-			
B.KL2		KLATKA SCHOD.	34,19	2,7	92,30	-	-	-	-	-			
<b>POZIOM +2</b>													
B.EN	2.01	POK. ASYSTENTA	23,82	2,7	64,31	1,5	22	20	110	110	B-N14	B-W14	
B.EN	2.02	MAGAZYN	7,33	2,7	19,79	1,8	-	20	0	40	z B-EN_2.05	B-W13	
B.EN	2.03	POM. ELEKTRYCZNE	7,63	3,0	22,89	1,7	20	16	40	40	B-N6	B-W6	
B.EN	2.04	POM. TELETECHNICZNE	3,99	3,0	11,97	1,7	20	16	20	20	B-N6	B-W6	
B.EN	2.05	SALA SEMINARYJNA / ODPRAW	43,04	3,0	129,12	6,0	20	20	780	740	B-N13	B-W13	REGULATOR - STEROWANIE WG. POZIOMU CO2
B.EN	2.06	SALA SEMINARYJNA / ODPRAW	45,72	3,0	137,16	5,7	20	20	780	780	B-N13	B-W13	REGULATOR - STEROWANIE WG. POZIOMU CO2
B.EN	2.07	POK. ASYSTENTA	23,31	3,0	69,93	1,6	22	20	110	110	B-N14	B-W14	
B.EN	2.08	KOMUNIKACJA	79,64	3,0	238,92	1,5	20	20	360	230	B-N6	B-W6	
B.EN	2.09	POM. TECHNICZNE	4,72	3,0	14,16	2,1	20	20	30	30	B-N6	B-W6	
B.EN	2.10	P. ODCINKA DOLN.	33,39	3,0	100,17	6,1	22	24	540	610	B-N10	B-W10	
B.EN	2.11	ŚLUZA	6,37	2,7	17,20	5,2	22	20	100	0	B-N10	do B-EN_2.10	
B.EN	2.12	ŁAZIENKA	5,30	2,5	13,25	6,3	-	24	0	100	z B-EN_2.10	B-WC1	
B.EN	2.13	P. ODCINKA DOLN.	26,36	3,0	79,08	6,2	22	24	440	490	B-N10	B-W10	
B.EN	2.14	ŚLUZA	6,02	2,7	16,25	6,1	22	20	110	0	B-N10	do B-EN_2.13	
B.EN	2.15	ŁAZIENKA	4,69	2,5	11,73	7,1	-	24	0	100	z B-EN_2.13	B-WC1	
B.EN	2.16	P. ODCINKA DOLN.	26,30	3,0	78,90	6,2	22	24	440	490	B-N10	B-W10	
B.EN	2.17	ŚLUZA	5,48	2,7	14,80	6,1	22	20	100	0	B-N10	do B-EN_2.16	
B.EN	2.18	ŁAZIENKA	4,43	2,5	11,08	7,5	-	24	0	100	z B-EN_2.16	B-WC1	
B.EN	2.19	POM. PORZĄDKOWE	2,43	2,7	6,56	4,1	-	20	0	30	z B-EN_2.20	B-WC1	
B.EN	2.20	KORYTARZ WEWNĘTRZNY	22,37	2,7	60,40	1,6	22	20	80	110	B-N10	B-W10	
B.EN	2.21	POM. MYCIA I DEZYNFEKCJI (cz.brudna)	37,91	2,7	102,36	10,0	20	20	780	1140	B-N4	B-W4	
B.EN	2.21	POM. MYCIA I DEZYNFEKCJI (cz.czysta)	16,30	2,7	44,01	10,0	20	20	490	430	B-N4	B-W4	
B.EN	2.22	MYCIE WÓZKÓW	6,02	2,7	16,25	5,5	20	20	90	100	B-N6	B-WC1	
B.EN	2.23	WPROWADZENIE MAT. BRUDNEGO	6,41	2,7	17,31	2,1	-	20	0	40	z B-EN_2.73	B-WC1	
B.EN	2.24	ŚRODKI TRANSPORTOWE CZYSTE	6,59	2,7	17,79	5,1	-	20	0	90	z B-EN_2.21	B-W4	
B.EN	2.25	ŚLUZA PERSONELU	13,15	2,7	35,51	3,0	20	20	120	0	B-N6	do B-EN_2.21	
B.EN	2.26	P. ODCINKA GÓRN.	21,94	3,0	65,82	6,2	22	24	360	410	B-N10	B-W10	
B.EN	2.27	P. ODCINKA GÓRN.	19,94	3,0	59,82	6,4	22	24	340	380	B-N10	B-W10	
B.EN	2.28	P. ODCINKA GÓRN.	26,72	3,0	80,16	6,2	22	24	450	500	B-N10	B-W10	
B.EN	2.28	RIT	-	-	0,00	-	-	-	-	30	z pom. B-EN_2.72	B-W6	

NR		POMIESZCZENIE	POW.	WYS.	KUB.	KROTNOŚĆ WYMIAN	T naw. zima	T w pom. zima	Vnaw	Vwyw	AHU naw	AHU wyw	UWAGI
[-]		[-]	[m <sup>2</sup> ]	[m]	[m <sup>3</sup> ]	[1/h]	[C]	[C]	[m <sup>3</sup> /h]	[m <sup>3</sup> /h]	[-]	[-]	[-]
B.EN	2.28A	KORYTARZ WEWNĘTRZNY	15,95	2,7	43,07	2,1	22	20	40	100	B-N10	B-W10	
B.EN	2.29	WC DLA OS. NIEPELNOSPRAWNYCH	9,40	2,5	23,50	4,3	-	20	0	120	z B-EN_2.72	B-WC1	
B.EN	2.30	REJESTRACJA	13,79	2,7	37,23	2,2	20	20	90	90	B-N6	B-W6	
B.EN	2.31	ZAPLECZE	13,33	2,7	35,99	1,8	20	20	70	70	B-N6	B-W6	
B.EN	2.32	ARCHIWUM	14,87	2,7	40,15	2,0	-	20	0	90	z B-EN_2.73	B-W6	
B.EN	2.33	POM. ELEKTRYCZNE	5,07	3,0	15,21	2,6	20	16	40	40	B-N6	B-W6	
B.EN	2.34	POM. TELETECHNICZNE	5,15	3,0	15,45	2,6	20	16	40	40	B-N6	B-W6	
B.EN	2.35	POM. PRZYG. PACJENTA	10,82	2,7	29,21	4,3	22	24	140	140	B-N10	B-W10	
B.EN	2.36	POM. PRZYG. PACJENTA	10,66	3,0	31,98	4,4	22	24	140	140	B-N10	B-W10	
B.EN	2.37	POCZEKALNIA	32,09	3,0	96,27	8,7	20	20	840	0	B-N6	B-W6	
B.EN	2.38a	WC PACJENCI M./WC	6,33	2,5	15,83	5,1	-	20	0	80	z B-EN_2.37	B-WC1	
B.EN	2.38	WC PACJENCI M.	3,81	2,5	9,53	-	-	-	-	-	z B-EN_2.37	B-WC1	
B.EN	2.39A	WC PACJENCI D.	6,32	2,5	15,80	6,3	-	20	0	100	z B-EN_2.37	B-WC1	
B.EN	2.39	WC PACJENCI D. / WC	3,81	2,5	9,53	-	-	-	-	-	z B-EN_2.37	B-WC1	
B.EN	2.40	MAG. SPRZĘTU	9,86	2,7	26,62	1,7	-	20	0	50	z B-EN_2.37	B-W6	
B.EN	2.41	MAG. SPRZĘTU	9,86	2,7	26,62	1,7	-	20	0	50	z B-EN_2.74	B-W6	
B.EN	2.42	WC PERSONELU MĘSKI	3,84	2,5	9,60	8,3	-	20	0	80	z B-EN_2.45	B-WC1	
B.EN	2.42A	WC PERSONELU MĘSKI / WC	5,93	2,5	14,83	-	-	-	-	-	z B-EN_2.45	B-WC1	
B.EN	2.43	WC PERSONELU DAMSKI	3,54	2,5	8,85	5,6	-	20	0	50	z B-EN_2,45	B-WC1	
B.EN	2.43A	WC PERSONELU DAMSKI / WC	3,01	2,5	7,53	-	-	-	-	-	z B-EN_2,45	B-WC1	
B.EN	2.44	BRUDOWNIK	3,86	2,5	9,65	4,3	-	20	0	50	z B-EN_2.74	B-WC1	
B.EN	2.45	KOMUNIKACJA	15,84	2,7	42,77	2,7	20	20	130	0	B-N6	do B-EN_2.42;43	
B.EN	2.46	ULTR. P. POKARM.	23,38	3,0	70,14	6,6	22	24	410	460	B-N10	B-W10	
B.EN	2.47	POK. SOC.JALNY	19,20	3,0	57,60	2,1	20	20	100	120	B-N6	B-WK1	
B.EN	2.48	POM. PORZĄDKOWE	5,36	2,7	14,47	3,7	-	20	0	60	z B-EN_2.73	B-WC1	
B.EN	2.49	POM. PRZYG. PACJENTA	12,06	2,7	32,56	4,1	22	24	150	150	B-N10	B-W10	
B.EN	2.50	BRUDOWNIK	5,47	2,7	14,77	4,3	-	20	0	70	z B-EN_2.73	B-WB1	
B.EN	2.51	MAG. BIEL. BRUDNEJ	5,53	2,7	14,93	4,2	-	20	0	70	z B-EN_2.73	B-WB1	
B.EN	2.52	POM. PRZYG. PACJENTA	12,26	2,7	33,10	4,1	22	24	150	150	B-N10	B-W10	
B.EN	2.53	MAG. SPRZĘTU	6,90	2,7	18,63	1,9	-	20	0	40	z B-EN_2.74	B-W6	
B.EN	2.54	MAG. BIEL. CZYSTEJ	6,00	2,7	16,20	2,2	-	20	40	0	B-N6	do B-EN_2.73	
B.EN	2.55	WC PERSONELU MĘSKI	3,58	2,5	8,95	7,4	-	20	0	80	z B-EN_2.08	B-WC1	
B.EN	2.55A	WC PERSONELU MĘSKI / WC	5,66	2,5	14,15	-	-	-	-	-	z B-EN_2.08	B-WC1	
B.EN	2.56	WC PERSONELU DAMSKI	2,23	2,5	5,58	9,0	-	20	0	50	z B-EN_2.08	B-WC1	
B.EN	2.56A	WC PERSONELU DAMSKI/ WC	1,88	2,5	4,70	-	-	-	-	-	z B-EN_2.08	B-WC1	
B.EN	2.57	POM. PORZĄDKOWE	3,20	2,5	8,00	5,2	-	20	0	50	z B-EN_2.74	B-W6	
B.EN	2.58	GABINET ENDO RTG	34,37	3,0	103,11	6,2	22	24	570	640	B-N10	B-W10	
B.EN	2.59	POK. OPISÓW	17,56	2,7	47,41	1,5	22	20	80	80	B-N14	B-W14	
B.EN	2.61	GABINET ENDO RTG	29,43	3,0	88,29	6,1	22	24	480	540	B-N10	B-W10	
B.EN	2.62	END.D.ODDECHOW.	23,87	3,0	71,61	6,3	22	24	400	450	B-N10	B-W10	
B.EN	2.63	ULTR. D. ODDECH.	23,41	3,0	70,23	6,4	22	24	400	450	B-N10	B-W10	
B.EN	2.64	SALA WYBUDZEŃ	128,46	3,0	385,38	10,0	24	24	3860	3470	B-N15	B-W15	
B.EN	2.65	POK. KIEROWNIKA	17,24	3,0	51,72	1,9	22	20	100	0	B-N14	do B-EN_2.66	
B.EN	2.66	ŁAZIENKA	4,40	3,0	13,20	7,6	-	24	0	100	z B-EN_2,65	B-WC1	
B.EN	2.67	SEKRETARIAT	23,19	3,0	69,57	1,6	22	20	110	110	B-N14	B-W14	

NR		POMIESZCZENIE	POW.	WYS.	KUB.	KROTNOŚĆ WYMIAN	T naw. zima	T w pom. zima	Vnaw	Vwyw	AHU naw	AHU wyw	UWAGI
[-]		[-]	[m <sup>2</sup> ]	[m]	[m <sup>3</sup> ]	[1/h]	[C]	[C]	[m <sup>3</sup> /h]	[m <sup>3</sup> /h]	[-]	[-]	[-]
B.EN	2.68	POK. LEKARZY	23,43	3,0	70,29	1,6	22	20	110	110	B-N14	B-W14	
B.EN	2.69	POK. PIELEŃNIAREK	22,95	3,0	68,85	1,6	22	20	110	110	B-N14	B-W14	
B.EN	2.70	POK. BIUROWY	22,75	3,0	68,25	1,6	22	20	110	110	B-N14	B-W14	
B.EN	2.71	KOMUNIKACJA	41,69	2,5	104,23	1,5	20	20	190	190	B-N6	B-W6	
B.EN	2.72	KOMUNIKACJA	33,34	2,5	83,35	1,5	20	20	150	0	B-N6	do B-EN_2,29	
B.EN	2.73	KOMUNIKACJA	105,65	2,5	264,13	1,6	20	20	500	0	B-N6	B-W6	
B.EN	2.27	RIT	-	-	0,00	-	-	-	-	30	Z POM. B-EN_2.73	B-W6	
B.EN	2.16	RIT	-	-	0,00	-	-	-	-	30	Z POM. B-EN_2.73	B-W6	
B.EN	2.74	KOMUNIKACJA	97,85	2,5	244,63	1,5	20	20	430	290	B-N6	B-W6	
B.EN	2.63	RIT	-	-	0,00	-	-	-	-	30	Z POM. B-EN_2.74	B-W6	
B.EN	2.46	RIT	-	-	0,00	-	-	-	-	30	Z POM. B-EN_2.74	B-W6	
B.EN	2.59	RIT			0,00		20	20		40	B-N6	B-W6	
B.KL1		KLATKA SCHOD.	23,47	3,0	70,41	-	-	-	-	-			
B.KL2		KLATKA SCHOD.	24,83	3,0	74,49	-	-	-	-	-			
<b>POZIOM +3</b>													
B	3.2	POW. TECH. DACH	264,28	3,0	792,84	-	-	-	-	-			