

NR		POMIESZCZENIE	POW.	WYS.	KUB.	KROTNOŚĆ WYMIAN	T naw. zima	T w pom. zima	Vnaw	Vwyw	AHU naw	AHU wyw	UWAGI
[-]		[-]	[m ²]	[m]	[m ³]	[1/h]	[C]	[C]	[m ³ /h]	[m ³ /h]	[-]	[-]	[-]
POZIOM -1													
B	-1.01	REZERWA / MAGAZYN	409,17	2,7	1104,8	3,7	16	16	4100	4100	B-NR1	B-WR1	
B	-1.02	REZERWA / MAGAZYN	171,68	2,7	463,54	2,4	16	16	1100	1100	B-NR2	B-WR2	
F.MAG	-1.26A	KOMUNIKACJA	89,40	2,5	223,50	1,5	20	20	340	340	B-N6	B-W6	
B.MN	-1.01	POK. KIEROWNIKA	15,43	3,0	46,29	2,6	22	20	120	50	B-N14	B-W14	
B.MN	-1.01	ŚLUZA DOZYMTRYCZNA	7,13	3,0	21,39	6,1	20	20	110	130	C-N1	C-W1	
B.MN	-1.01A	SZATNIA	6,32	3,0	18,96	5,3	20	24	100	0	C-N1	z pom. B.MN-1.01B	
B.MN	-1.01B	UMYWALNIA	5,57	3,0	16,71	6,0	-	24	0	100	z pom. B.MN-1.01A	C-WC1	
B.MN	-1.01C	SZATNIA	6,32	3,0	18,96	5,3	20	24	100	0	C-N1	z pom. B.MN-1.01D	
B.MN	-1.01D	UMYWALNIA	5,79	3,0	17,37	5,8	-	24	0	100	z pom. B.MN-1.01C	C-WC1	
B.MN	-1.02	ŁAZIENKA	3,92	2,5	9,80	7,1	-	24	0	70	z B-MN_-1,01	B-WC1	
B.MN	-1.03	SEKRETARIAT	23,29	3,0	70,47	1,6	22	20	110	80	B-N14	B-W14	
B.MN	-1.04	ZAPLECZE	2,23	3,0	6,69	4,5	-	20	0	30	z B-MN_-1,03	B-W14	
B.MN	-1.05	KORYTARZ TECHNICZNY	83,49	2,5	208,73	1,8	20	16	380	180	B-N6	B-W6	
B.MN	-1.06	POM. ELEKTRYCZNE	7,63	3,0	23,16	2,2	20	16	50	50	B-N6	B-W6	
B.MN	-1.07	POM. TELETECHNICZNE	3,98	3,0	11,91	4,2	20	16	50	50	B-N6	B-W6	
B.MN	-1.08	ADMINISTRACJA	23,57	3,0	70,38	1,6	22	20	110	110	B-N14	B-W14	
B.MN	-1.11	POM. SZKOLENIOWE	19,39	3,0	58,41	7,7	20	20	450	450	B-N6	B-W6	
B.MN	-1.15	POKÓJ OPISÓW	24,13	3,0	72,90	1,6	20	22	120	120	B-N14	B-W14	
B.MN	-1.16	POKÓJ OPISÓW	24,97	3,0	74,91	1,6	20	22	120	120	B-N14	B-W14	
B.MN	-1.17	WC MĘSKI	7,05	3,0	21,72	4,6	-	20	0	100	z B-MN_-1,18	B-WC1	
B.MN	-1.18	POCZEKALNIA	26,87	3,0	80,49	5,0	20	20	400	200	B-N6	B-W6	
B.MN	-1.19	WC DAMSKI	6,77	3,0	19,44	5,1	-	20	0	100	z B-MN_-1,18	B-WC1	
B.MN	-1.20	PRÓBY WYSIŁKOWE	24,46	3,0	73,26	2,0	22	24	130	150	B-N14	B-W14	
B.MN	-1.21	POM. SOCJALNE	25,01	3,0	75,24	4,8	20	20	270	360	B-N6	B-WK1	
B.MN	-1.22	GAB. BADAŃ	21,56	3,0	65,73	2,1	22	24	140	140	B-N14	B-W14	
B.MN	-1.23	GAB. BADAŃ	21,83	3,0	65,73	2,1	22	24	140	140	B-N14	B-W14	
B.MN	-1.24	REJESTRACJA	14,11	3,0	42,27	1,7	20	20	70	0	B-N6	z B.MN-1.73	
B.MN	-1.25	POCZTA PNEUMATYCZNA	1,25	3,0	3,72	-	-	-	-	-			
B.MN	-1.26	REJESTRACJA ZAPLECZE	13,51	3,0	41,37	1,7	20	20	60	70	B-N6	B-W6	
B.MN	-1.27	WC DAMSKI PRZEDSIONEK	3,56	3,0	11,04	-	-	-	-	-			
B.MN	-1.27A	WC DAMSKI WC	2,66	3,0	7,95	6,3	-	20	0	50	z B-MN_-1,73	B-WC1	
B.MN	-1.28	WC MĘSKI PRZEDSIONEK	3,05	3,0	9,27	-	-	-	-	-			
B.MN	-1.28A	WC MĘSKI WC	3,66	3,0	11,31	7,1	-	20	0	80	z B-MN_-1,73	B-WC1	
B.MN	-1.29	WC PACJENCI D.	3,78	3,0	15,06	3,3	-	20	0	50	z B-MN_-1,36A	B-WC1	
B.MN	-1.29A	WC DLA NIEPEŁNOSPRAWNYCH	4,74	3,0	15,09	6,6	-	20	0	100	z B-MN_-1,36A	B-WC1	
B.MN	-1.31	KABINA	3,96	3,0	11,88	2,5	-	20	0	30	z B-MN_-1,36	B-W3	
B.MN	-1.31A	KABINA	4,00	3,0	12,00	2,5	-	20	0	30	z B-MN_-1,36	B-W3	
B.MN	-1.31B	KABINA	2,19	3,0	6,51	4,6	-	20	0	30	z B-MN_-1,36	B-W3	
B.MN	-1.32	KABINA	2,20	3,0	6,51	4,6	-	20	0	30	z B-MN_-1,36	B-W3	
B.MN	-1.33	KABINA	4,03	3,0	11,88	2,5	-	20	0	30	z B-MN_-1,36	B-W3	
B.MN	-1.34	KABINA	3,90	3,0	11,52	2,6	-	20	0	30	z B-MN_-1,36	B-W3	
B.MN	-1.35	KABINA	3,99	3,0	11,88	2,5	-	20	0	30	z B-MN_-1,36	B-W3	

NR		POMIESZCZENIE	POW.	WYS.	KUB.	KROTNOŚĆ WYMIAN	T naw. zima	T w pom. zima	Vnaw	Vwyw	AHU naw	AHU wyw	UWAGI
[-]		[-]	[m ²]	[m]	[m ³]	[1/h]	[C]	[C]	[m ³ /h]	[m ³ /h]	[-]	[-]	[-]
B.MN	-1.36	POCZEKALNIA GORAÇA	19,82	3,0	59,34	3,5	24	20	210	0	B-N3	z kabin	
B.MN	-1.36A	PRZEDSIONEK	11,12	3,0	33,33	7,2	24	20	240	0	B-N3	z sąsiednich pom.	
B.MN	-1.36B	POCZEKALNIA ZIMNA	16,65	3,0	49,95	2,4	24	20	120	120	B-N3	B-W3	
B.MN	-1.37	PRZEDSIONEK	10,78	3,0	32,67	9,5	24	20	310	0	B-N3	do -1.64; -1.61	
B.MN	-1.38	APLIKACJA	9,78	3,0	30,51	6,2	24	20	170	190	B-N3	B-W3	filtr H11 na wyciągu
B.MN	-1.39	APLIKACJA	10,81	3,0	32,70	5,5	24	20	180	100	B-N3	B-W3	filtr H11 na wyciągu
B.MN	-1.40	ŁAZIENKA	2,53	3,0	7,74	12,9	-	24	0	100	z B-MN_-1,36A	B-WCI1	
B.MN	-1.41	APLIKACJA	10,76	3,0	32,67	6,1	24	20	180	200	B-N8	B-W8	filtr H11 na wyciągu
B.MN	-1.42	APLIKACJA	10,42	3,0	31,59	6,0	24	20	170	190	B-N8	B-W8	filtr H11 na wyciągu
B.MN	-1.42A	ŁAZIENKA	4,38	3,0	13,11	7,6	-	24	0	100	z B-MN_-1.44	B-WCI1	
B.MN	-1.43	POCZEKALNIA GORAÇA	15,16	3,0	45,39	4,8	24	20	220	220	B-N8	B-W8	
B.MN	-1.44	POCZEKALNIA GORAÇA	43,27	3,0	129,15	2,4	24	20	310	0	B-N8	do sąsiednich pom.	
B.MN	-1.45	PRZEDSIONEK	11,53	3,0	34,44	4,1	24	20	140	0	B-N8	z sąsiednich pom.	
B.MN	-1.46	WC PACJENCI D.	5,12	3,0	16,77	6,0	-	20	0	100	z B-MN_-1,44	B-WCI1	
B.MN	-1.47	WC PACJENCI M.	7,20	3,0	21,72	4,6	-	20	0	100	z B-MN_-1,44	B-WCI1	
B.MN	-1.48	WC PERSONELU DAMSKI PRZEDSIONEK	2,84	3,0	8,97	-	-	-	-	-			
B.MN	-1.48A	WC PERSONELU DAMSKI WC	2,15	3,0	6,45	7,8	-	20	0	50	z B-MN_-1,70	B-WC1	
B.MN	-1.49	WC PERSONELU MĘSKI PRZEDSIONEK	3,14	3,0	9,54	-	-	-	-	-			
B.MN	-1.49A	WC PERSONELU MĘSKI WC	5,74	3,0	17,22	4,6	-	20	0	80	z B-MN_-1,70	B-WC1	
B.MN	-1.50	GAMMA KAMERA	50,09	3,0	151,26	6,0	24	20	770	910	B-N8	B-W8	
B.MN	-1.51	UPS	13,33	3,0	39,99	1,3	24	20	50	50	B-N6	B-W6	
B.MN	-1.52	STEROWNIA	22,53	3,0	67,59	3,1	24	20	210	140	B-N8	B-W8	
B.MN	-1.53	SPEC / CT	48,78	3,0	147,24	6,0	24	20	750	890	B-N8	B-W8	
B.MN	-1.54	UPS	11,48	3	34,44	1,5	24	20	50	50	B-N6	B-W6	
B.MN	-1.55	PRZYGOTOWANIE RADIOFARM.	40,60	2,7	110,73	20,0	22	20	1990	2220	B-N2	B-W2	filtr H14 na nawiewie i na wyciągu
		komory do radiofarmaceutyków	-	-	-	-	-	-	-	250		B-WKR1	
		komory do radiofarmaceutyków	-	-	-	-	-	-	-	250		B-WKR2	
		komory do radiofarmaceutyków	-	-	-	-	-	-	-	250		B-WKR3	
		komory do radiofarmaceutyków	-	-	-	-	-	-	-	250		B-WKR4	
B.MN	-1.56	KONTROLA JAKOŚCI	20,92	3,0	52,17	16,3	22	20	850	800	B-N2	B-W2	filtr H11na nawiewie i na wyciągu
		ODCIĄG RADIOCHEMICZNY	-	-	-	-	-	-	-	800		B-WWR	
B.MN	-1.57	MAG. ŹRÓDEŁ PROM.	18,16	3,0	54,48	6,1	22	20	290	330	B-N2	B-WMI1	klapa zwrotna na nawiewie, filtr H11 na wywiewie
B.MN	-1.58	MAG. ODP.PROM.	12,53	3,0	33,45	6,3	22	20	180	210	B-N2	B-WMI1	klapa zwrotna na nawiewie, filtr H11 na na wywiewie
B.MN	-1.59	ŚLUZA DOZYMTRYCZNA	10,23	3,0	32,13	2,2	22	20	70	60	B-N2	B-W2	
B.MN	-1.61	PET / CT	65,96	3,0	198,81	6,0	24	20	990	1200	B-N3	B-W3	
B.MN	-1.62	UPS	7,20	3,0	21,60	2,3	24	20	50	50	B-N3	B-W3	
B.MN	-1.63	STEROWNIA	23,52	3,0	70,56	3,0	24	20	210	120	B-N3	B-W3	
B.MN	-1.64	PET / MRI	66,87	3,0	200,61	11,5	24	20	2000	2300	B-N3	B-W3	
		recyrkulacja	-	-	-	-	-	-	2560	2560			KLIMAKONWEKTOR KANAŁOWY
B.MN	-1.65	PRACOWNIA RADIOIMMUNOLOGII	15,42	3,0	49,38	6,1	20	20	300	300	B-N6	B-W6	